


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



IAPMO R&T Product Listing



This IAPMO R&T Listing is current as of 12/2/2020

Product: Microbiological Water Purifier

File No. W-12270

Issued To: WATERLOGIC INTERNATIONAL LTD
1 GRENFELL ROAD
MAIDENHEAD, XX BERKSHIRESL6 1HN
UNITED KINGDOM

Identification: The product or packaging shall be marked with the model number, name and address or manufacturer, functional description of system, max operating temperature, max working pressure, a statement noting that the system conforms to the EPA Guide Standard and Protocol for Testing Microbiological Water Purifiers. Product shall bear the cUPC® certification mark.

Characteristics: The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of microbiological organisms (bacteria, virus, and cyst) that may be present in drinking water of unknown quality which are considered health hazards. To be used and installed in accordance with the manufacturer's instructions and the requirements of the latest edition of the Uniform Plumbing Code and the National Plumbing Code of Canada.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following standard(s):

US EPA Guide Standard and Protocol for Testing Microbiological Water Purifiers

Product Type: Plumbed In without Reservoir

<u>Brand Name</u>	<u>Model Number</u>	<u>Replacement Component</u>	<u>Capacity (Gallons)</u>	<u>Flow Rate (GPM)</u>	<u>Reduction Claims</u>
Firewall 2	Firewall 2 ¹	CT-2085-X/15W-2FW bulb	2000	0.42	Bacteria, Virus, Cyst
Firewall 4	Firewall 4 ¹	CT-2090-X	2000	0.42	Bacteria, Virus, Cyst

Product Type: Point - of - use

<u>Brand Name</u>	<u>Model Number</u>	<u>Replacement Component</u>	<u>Capacity (Gallons)</u>	<u>Flow Rate (GPM)</u>	<u>Reduction Claims</u>
Edge/Hybrid	Edge Mark II/ Hybrid II ^{1,2}	CT-2090-X	2500	0.42	Bacteria, Virus, Cyst
Edge/Hybrid	Edge / Hybrid ^{1,2}	CT-2090-X	2500	0.42	Bacteria, Virus, Cyst
HORECA Firewall	HORECA Firewall ^{1,4}	CT-2085-X	2000	3.51pm	Bacteria, Virus, Cyst
WL2 FX	12-CHCFW3-YYY ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	12-CHCMFW3-YYY ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst

WL2 FX	WL2 FL FX C ^{1,3}	CT-2085-X	2000	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX CA ^{1,3}	CT-2085-X	2000	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX HC ^{1,3}	CT-2085-X	2000	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX MC ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX MC ^{1,3}	CT-2085-X	2500	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX MCA ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX MCA ^{1,3}	CT-2085-X	2500	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX MHC ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FL FX MHC ^{1,3}	CT-2085-X	2500	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX C ^{1,3}	CT-2085-X	2000	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX CA ^{1,3}	CT-2085-X	2000	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX HC ^{1,3}	CT-2085-X	2000	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX MC ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX MC ^{1,3}	CT-2085-X	2500	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX MCA ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX MCA ^{1,3}	CT-2085-X	2500	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX MHC ^{1,3}	CT-2085-X	1250	0.42	Bacteria, Virus, Cyst
WL2 FX	WL2 FX MHC ^{1,3}	CT-2085-X	2500	0.42	Bacteria, Virus, Cyst

Product Type: Plumbed-In with Storage Tank or Reservoir

<u>Brand Name</u>	<u>Model Number</u>	<u>Replacement Component</u>	<u>Capacity (Gallons)</u>	<u>Flow Rate (GPM)</u>	<u>Reduction Claims</u>
CUBE/ Countertop	CUBE 1 / Countertop 1 ^{1,2}	CT-2090-X	2500	0.34	Bacteria, Virus, Cyst
CUBE/ Countertop	CUBE 2 / Countertop 2 ^{1,2}	CT-2090-X	2500	0.34	Bacteria, Virus, Cyst

¹ This model is available with either a phototransistor (European market), a CD monitor (European market), or UVC monitor (American market). For European market models that require a phototransistor, the UV light bulb must be replaced every 6 months by the consumer, otherwise the certification is void.

² This model is certified to NSF Protocol P231/US EPA Guide Standard only when equipped with FT-0004-L00-XXX or FT-0006-L00-XXX filter

³ Only the cold water portion of the unit is certified for microbiological claims.

⁴ This product is certified for a maximum flow rate of 3.5 liters per minute.

This IAPMO R&T Listing is current as of 12/2/2020