


IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761-2816 • (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



IAPMO R&T Product Listing



This IAPMO R&T Listing is current as of 12/2/2020

Product: Water Treatment Product - Health Effects File No. W-12263

Issued To: WATERLOGIC INTERNATIONAL LTD
 1 GRENFELL ROAD
 MAIDENHEAD, XX BERKSHIRESL6 1HN
 UNITED KINGDOM

Identification: The product shall be marked the name of the manufacturer, model designation, and the claims verified and substantiated by test data. The product shall also bear the cUPC certification mark.

Characteristics: The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private) which are considered health hazards. To be used in accordance with the manufacturer's instructions. To be installed in accordance with the latest edition of the Uniform Plumbing Code and the National Plumbing Code of Canada.

An elective claim per NSF/ANSI 53 (or P473) is PFOA and PFOS. Levels of PFOA and PFOS vary across different regions. When a product has been certified for PFOA/PFOS, the current acceptance level under NSF/ANSI 53 (or P473) is 70 ppt for both PFOA and PFOS. The combination of PFOS and PFOA cannot exceed the total.

Below are specific levels established by specific AHJs:

- US EPA, Alabama, Alaska, California, Colorado, Connecticut, Florida, Idaho Maine, Massachusetts, Michigan and West Virginia: 70 ppt for both PFOA and PFOS. The combination of PFOS and PFOA cannot exceed the total.
- Minnesota: 35 ppt for PFOA and 15 ppt for PFOS
- Nevada: 667 ppt for both PFOA and PFOS.
- New Hampshire: 12 ppt for PFOA and 15 ppt for PFOS.
- New Jersey: 14 ppt for PFOA and 13 ppt for PFOS.
- Vermont: 20 ppt for both PFOA and PFOS. The combination of PFOS and PFOA cannot exceed the total.
- Canada: 200 ppt for PFOA and 600 ppt for PFOS.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

Products are in compliance with the following standard(s):

NSF/ANSI 53-2018

Product Type: Point-of-Use

<u>Brand Name</u>	<u>Model Number</u>	<u>Replacement Component</u>	<u>Capacity (Gallons)</u>	<u>Flow Rate (GPM)</u>	<u>Reduction Claims</u>

CUBE/ Countertop	CUBE 1 / Countertop 1 ²	FT-0004-L00-WLT	2500	0.34	Asbestos, Cyst
CUBE/ Countertop	CUBE 1 / Countertop 1 ²	FT-0006-L00-WLT	1250	0.34	Asbestos, Cyst, Lead
CUBE/ Countertop	CUBE 2 / Countertop 2 ²	FT-0004-L00-WLT	2500	0.34	Asbestos, Cyst
CUBE/ Countertop	CUBE 2 / Countertop 2 ²	FT-0006-L00-WLT	1250	0.34	Asbestos, Cyst, Lead
Edge/ Hybrid	Edge Mark II / Hybrid II ²	FT-0004-L00-XXX	2500	0.42	Asbestos, Cyst
Edge/ Hybrid	Edge Mark II / Hybrid II ²	FT-0006-L00-XXX	1250	0.42	Asbestos, Cyst, Lead
Edge/ Hybrid	Edge / Hybrid ²	FT-0004-L00-XXX	2500	0.42	Asbestos, Cyst
Edge/ Hybrid	Edge / Hybrid ²	FT-0006-L00-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	12-CHCFW3-YYY ³	FT-0063-IL-XXX	1250	0.5	Asbestos, Cyst, Lead
WL2 FX	12-CHCMFW3- YYY ³	FT-0063-IL-XXX	1250	0.5	Asbestos, Cyst, Lead
WL2 FX	WL2 FL FX C ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FL FX C ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FL FX CA ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FL FX CA ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FL FX HC ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FL FX HC ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FL FX MC ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FL FX MC ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FL FX MCA ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FL FX MCA ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FL FX MHC ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FL FX MHC ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FX C ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FX C ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FX CA ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FX CA ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FX HC ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FX HC ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FX MC ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FX MC ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FX MCA ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FX MCA ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
WL2 FX	WL2 FX MHC ³	FT-0030-OM-XXX	2500	0.42	Asbestos, Cyst
WL2 FX	WL2 FX MHC ³	FT-0061-OM-XXX	1250	0.42	Asbestos, Cyst, Lead
Waterlogic 1 micron 10" CBC Lead Reduction Filter	FT-0061-OM-XXX ¹	FT-0064-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 1 micron 10" CBC Lead Reduction Filter	FT-0061-YW-XXX ¹	FT-0064-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 1 micron 10" CBC Lead Reduction Filter	FT-0063-IL-XXX ¹	FT-0064-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 10" CBC 1 micron Cyst Reduction and	FT-PP04-L00-XXX ¹	FT-PP36-XXX	2500	0.5	Asbestos, Cyst

Scale Inhibitor Filter					
Waterlogic 10" CBC 1 micron Cyst Reduction and Scale Inhibitor Filter	FT-PP30-OM-XXX ¹	FT-PP36-XXX	2500	0.5	Asbestos, Cyst
Waterlogic 10" CBC 1 micron Cyst Reduction and Scale Inhibitor Filter	FT-PP30-YW-XXX ¹	FT-PP36-XXX	2500	0.5	Asbestos, Cyst
Waterlogic 10" CBC 1 micron Cyst Reduction and Scale Inhibitor Filter	FT-PP34-IL-XXX ¹	FT-PP36-XXX	2500	0.5	Asbestos, Cyst
Waterlogic 10" CBC 1 micron Lead and Cyst Reduction and Scale Inhibitor Filter	FT-PP06-L00-XXX ¹	FT-PP64-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 10" CBC 1 micron Lead and Cyst Reduction and Scale Inhibitor Filter	FT-PP61-OM-XXX ¹	FT-PP64-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 10" CBC 1 micron Lead and Cyst Reduction and Scale Inhibitor Filter	FT-PP61-YW-XXX ¹	FT-PP64-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 10" CBC 1 micron Lead and Cyst Reduction and Scale Inhibitor Filter	FT-PP63-IL-XXX ¹	FT-PP64-XXX	1250	0.5	Asbestos, Cyst, Lead
Waterlogic 10" 1 Micron CBC	FT-0030-OM-XXX ¹	FT-0036-XXX	2500	0.5	Asbestos, Cyst
Waterlogic 10" 1 Micron CBC	FT-0030-YW-XXX ¹	FT-0036-XXX	2500	0.5	Asbestos, Cyst
Waterlogic 10" 1 Micron CBC	FT-0034-IL-XXX ¹	FT-0036-XXX	2500	0.5	Asbestos, Cyst
Waterlogic CICO 10" CBC	FT-0004-L00-XXX	FT-0036-XXX	2500	0.5	Asbestos, Cyst
Waterlogic CICO 10" CBC	FT-0006-L00-XXX	FT-0064-XXX	1250	0.5	Asbestos, Cyst, Lead

¹ Where "XXX" = any three letter customer code

² Where "XX" is the combination of the exterior colors: "WK" is white machine/ black reservoir; "SB" is silver machine/ black reservoir; "WB" is white machine/ blue reservoir; and "WR" is white machine/ red reservoir; SI is full silver. "YYY" is any three letter customer code. "YY" is any two letter customer code.

³ This model is available with either a phototransistor (European market) or UVC monitor (American market). For European market models that require a phototransistor monitor, the UV light bulb must be replaced every 6 months by the consumer, otherwise, the certification is void.

This IAPMO R&T Listing is current as of 12/2/2020